Landlord Gas Safety Record

Cert. No. 508

untingford Heating

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998 section 26(9) and the Gas Industry Unsafe Situations Procedure.

ompany / Installer

ngineer	Lee Pooley
ompany	Buntingford Heating
ddress	16
	Chequers Close
	Buntingford
	Herts
ost Code	SG99TB
el No.	01763772017
as Safe Reg	632515
D Card No.	632515

Job Address

Name	
Address	Barkway Village Hall
	Cambridge rd
	Barkway
Post Code	SG88BP
Tel. No	

Customer / Landlord

Name	
Company	Barkway Village Hall
Address	Barkway Village Hall
	Cambridge rd
	Barkway
Post Code	SG8 8BS
Tel. No	07768 526461

ppliance Details / Inspection Details

Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance sa to use
									Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
Kitchen	Chb	Vailant	Eco Max 835	RS	Yes	Yes	NA	NA	0.0010	88	9.2	NA	NA	NA	Yes	Yes	Yes	Pass	Yes	Yes

efects / Identified

Labels and Warning Notice Issued

1	Unable to gas rate due to faulty smart meter display	NA
2		
3		
4		
5		
6		

CO Alarm(s)

CO Alarm(s) fitted	Yes
CO Alarm(s) tested and Satisfactory	Pass

mergency Control Accessible Yes Gas Tightness Satisfactory Yes

as Installation Pipework Visual Inspection Satisfactory Yes

Equipotential Bonding Yes

EXT INSPECTION DUE BEFORE 24-Nov-2026

Comments

All ok

gnatures

Issued by: Signed



Print Name Lee Pooley

Received by: Signed

Print Name

Date 15-Nov-2025