Landlord Gas Safety Record

Cert. No. 577

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998 section 26(9) and the Gas Industry Unsafe Situations Procedure.

Buntingford Heating

Company / Installer

Engineer	Lee Pooley
Company	Buntingford Heating
Address	16
	Chequers Close
	Buntingford
	Herts
Post Code	SG99TB
Tel No.	01763772017
Gas Safe Reg	632515
ID Card No.	632515

Job Address

Name	
Address	Barkway Village Hall
	Cambridge rd
	Barkway
Post Code	SG88BP
Tel. No	

Customer / Landlord

Name	
Company	Barkway Village Hall
Address	Barkway Village Hall
	Cambridge rd
	Barkway
Post Code	SG8 8BS
Tel. No	07768 526461

Appliance Details / Inspection Details

	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Kitchen	Chb	Vailant	Eco Max 835	RS	Yes	Yes	NA	32	0.0005	54	9.2	NA	NA	NA	Yes	Yes	Yes	Pass	Yes	Yes
2																					
3																					
4																					
5																					
6																					

Defects / Identified

Labels and Warning Notice Issued

1		NA
2		
3		
4		
5		
6		

CO Alarm(s)

CO Alarm(s) fitted	Yes
CO Alarm(s) tested and Satisfactory	Pass

Emergency Control Accessible Yes Gas Tightness Satisfactory Yes

Gas Installation Pipework Visual Inspection Satisfactory Yes

Equipotential Bonding Yes

Comments

Signatures

Issued by: Signed 

Print Name: Lee Pooley

Received by: Signed 

Print Name

Date: 18-Nov-2026

NEXT INSPECTION DUE BEFORE: 24-Nov-2027